

कर्मचारी भविष्य निधि संगठन
(श्रम मंत्रालय :: भारत सरकार)
जलपाईगुड़ी क्षेत्र एवं सिक्किम
क्षेत्रीय कार्यालय, जलपाईगुड़ी
भविष्य निधि भवन, दिन बाजार,
जलपाईगुड़ी- 735101.



Employees Provident Fund Organisation
(Ministry of Labour, Govt. Of India)
Jalpaiguri Region & Sikkim
Regional Office, Jalpaiguri
Bhavishya Nidhi Bhawan, Din Bazar
Jalpaiguri - 735101.

ई-मेल / E-mail: ro.jalpaiguri@epfindia.gov.in
epfo_jalpaiguri@yahoo.co.in

दूरभाष सं./Phone No. 03561-230271/230731
फैक्स सं./ Fax No.03561-231241.

No.Adm./RO/JPG/ Moduler Furniture/371/ 563

Date : 23.07.2010

NOTICE INVITING TENDER FOR ESTIMATION FOR ELECTRICAL CABLING & INTERCOM CABLING IN REGIONAL OFFICE, JALPAIGURI & SUB-REGIONAL OFFICE, SILIGURI

The Office of the Regional Provident Fund Commissioner, Jalpaiguri is located at the addressed mentioned above in its own building. This office is having 1st floor to 04th floor. The office has identified around **180 nos.** work stations for Regional Office, Jalpaiguri and **120 nos.** work stations for its SRO, Siliguri in its own building for implementation of Computerisation project. Sealed tenders are invited from Government Agencies/ Semi-Govt. Agencies for carrying out the Electrical cabling and fixing of Modular Switches, Sockets alongwith MCBs, DBs, Earthing etc. and Intercom cabling at the following offices in Jalpaiguri Region :-

1. Regional Office, Jalpaiguri at Bhavishya Nidhi Bhawan, Din Bazar, Jalpaiguri-735101.
2. Sub-Regional Office, Siliguri, Bhavishya Nidhi Bhawan, Tenjing Norgey Central Bus Terminus, Hill Cart Road, Siliguri-734003.


The requirement of electrical work is briefly as below :-

1. Each work station should have two normal electrical power points (5/6Amp.) for 800VA UPS and printer.
2. For each station i.e. Accounts group, Compliance/ Enforcement, Pension etc. , there should be provision for one 15 Amp. Power point. All the materials should be of high quality / reputed brands and should confirm to ISI specifications.
3. Each work station will have one I/O box.
4. Electrical and Data Cabling should have recommended separation of 18inches (minimum 12 inches) and ideally should not cross each other in the cabling plans. If crossing over becomes inevitable, it should happen at 90 degree (Right Angle).
5. Two power points (15Amps.) should be provided near each work network rack location in every floor. The network rack location will be near the vertical shaft.
6. Proper earthing for electrical connections- the office building should be provided with proper earthing for the electrical connections. Separate earthing should be carried out for the server room and rest of the office.
7. Electrical load assessment : The electrical load for the office building may be assessed considering the present load and anticipated increase of load due to installation of computers and proposed air-conditioning. If necessary, additional load sanction will be obtained from the concerned authorities by this office.
8. The layout plans of modular furniture/ work stations in the office are available in this office.

Interested Government agencies/ Semi-Government Agencies may visit of the office premises and assess the work involved . Quotation/ detailed estimate alongwith Brand name of the material to be used for the above work, duly completed and supported with all relevant details/ documents in sealed cover superscribed as "**Quotation for Electrical Cabling for Computer Project & Intercom Cabling**" should be submitted to this office on or before **10th August 2010** addressed by name to Sri P.K.Mishra, RPF-I. Tender Notice may also be downloaded from the Official Website of the Organisation. The Offer/Bids will be opened on **12th August 2010 at 03P.M.** . The interested parties may attend the meeting. The work shall be carried out as per the CPWD specifications, Procedures duly following the GFR Provisions and CVC guidelines.

The Employees Provident Fund Organisation reserves the right to refuse/ reject any or all of the quotation(s) without assigning any reason thereof.

Jalpaiguri
Date : 23.07.2010


(P.K. Mishra)
Regional P.F. Commissioner-I